

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-1408:109

Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Signal Communications Corporation, 4 Wheeling Ave., Woburn, MA 01801  
Contact: Nadim Farhat (781) 933-0998 Fax (781) 933-5019

**DESIGN:** Models AU551-S, AU551-F, AU552-S and AU552-F speakers. Suitable for outdoor use with weatherproof backbox. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as speakers for use with separately listed compatible control units.  
If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's installation Instructions Manual for details.

**NOTE:** Formerly 7320-1083:102

**XLf:** 7320-1173:100

05-10-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2005**

*Listing Expires **June 30, 2006***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**