

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7151-1408:112 Page 1 of 1

**CATEGORY:** Boxes/Pull Stations for Hazardous Location

**LISTEE:** Signal Communications Corp., 4 Wheeling Avenue, Woburn, MA 01801  
Contact: Nadim Farhat (781) 933-0998 Fax (781) 933-5019

**DESIGN:** Model SGX-32 fire alarm manual pull station. Suitable for use in Class I, Groups B, C and D; Class II, Groups E, F, and G hazardous locations, type 4X enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120 VAC, 30 VDC

**INSTALLATION:** In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as manual pull station for use with separately listed and compatible fire alarm control units. Suitable for use in Class I, Groups B, C and D; Class II, Groups E, F, and G hazardous locations. Also suitable for use in marine locations.

04-03-2000



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2005**

*Listing Expires **June 30, 2006***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**